

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (6.6E-01)	ND (6.6E-01)	Treated water tank	Jun 20, 2014	11:30 AM
Cs-137	ND (6.6E-01)	ND (7.8E-01)			
Gross β	ND (9.4E-01)	ND (8.9E-01)			
Tritium	8.0E+02	6.9E+02	Receiving tank	Jun 18, 2014	10:00 AM
Notification density rate*	0.063	0.061			

<Desalination RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (6.1E-01)	ND (9.2E-01)	Treated water tank	Jun 20, 2014	3:05 PM
Cs-137	9.6E-01	ND (9.3E-01)			
Gross β	ND (4.7E+00)	3.7E+00			
Tritium	1.7E+02	1.4E+02	Receiving tank	Jun 19, 2014	10:00 AM
Notification density rate*	0.18	0.15			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.