

Radioactive Material Density in the Air at the Place Where Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System is Sprinkled and Ambient Dose Rate at the Surrounding Area

○The place No.1 where rainwater is sprinkled (Data summarized on June 28)

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]	Measurement date
Radioactive material density in the air (Particle)	Cs-134      ND (2.7E-6)	Jun 27, 2014      12:51 PM ~ 1:01 PM *1
	Cs-137      ND (3.9E-6)	
	Cs-134      ND (2.6E-6)	Jun 27, 2014      2:05 PM ~ 2:15 PM *2
	Cs-137      ND (4.0E-6)	

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date
Ambient dose rate	0.010	Jun 27, 2014      12:55 PM      *1
	0.010	Jun 27, 2014      2:08 PM      *2

\*1 The sampling and measurement was performed before sprinkling treated water.

\*2 The sampling and measurement was performed during sprinkling treated water.

Ends