

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (6.8E-01)	ND (6.2E-01)	Treated water tank	Jul 9, 2014	3:30 PM
Cs-137	ND (4.6E-01)	ND (8.7E-01)			
Gross β	ND (3.9E+00)	ND (4.8E+00)			
Tritium	2.2E+02	1.7E+02	Receiving tank	Jul 7, 2014	10:30 AM
Notification density rate*	0.15	0.18			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.