

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

| | Measurement result [Bq/L] | | Sampling place | Sampling date | Sampling time |
|----------------------------|------------------------------|----------------------------|--------------------|---------------|---------------|
| | Chemical Analysis Building * | Laboratory at Unit 5 and 6 | | | |
| Cs-134 | ND (6.5E-01) | ND (4.3E-01) | Treated water tank | Jul 24, 2014 | 3:30 PM |
| Cs-137 | ND (7.5E-01) | ND (6.6E-01) | | | |
| Gross β | ND (3.9E+00) | ND (4.8E+00) | | | |
| Tritium | 1.5E+02 | 1.4E+02 | Receiving tank | Jul 22, 2014 | 10:20 AM |
| Notification density rate* | 0.15 | 0.18 | | | |

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.