

Radioactive Material Density in the Air at the Place Where Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System is Sprinkled and Ambient Dose Rate at the Surrounding Area (1/2)

○The place No.1 where rainwater is sprinkled (Data summarized on August 1)

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]		Measurement date	
Radioactive material density in the air (Particle)	Cs-134	ND (2.4E-6)	Jul 31, 2014	8:20 AM ~ 8:30 AM
	Cs-137	ND (2.0E-6)		

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date	
Ambient dose rate	0.008	Jul 31, 2014	8:20 AM

○The place No.2 where rainwater is sprinkled

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]		Measurement date	
Radioactive material density in the air (Particle)	Cs-134	ND (2.5E-6)	Jul 31, 2014	9:15 AM ~ 9:25 AM
	Cs-137	ND (1.9E-6)		

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date	
Ambient dose rate	0.012	Jul 31, 2014	9:15 AM

Radioactive Material Density in the Air at the Place Where Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System is Sprinkled and Ambient Dose Rate at the Surrounding Area (2/2)

○The place No.3 where rainwater is sprinkled

(Data summarized on August 1)

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]		Measurement date	
Radioactive material density in the air (Particle)	Cs-134	ND (1.9E-6)	Jul 31, 2014	9:00 AM ~ 9:10 AM
	Cs-137	ND (2.3E-6)		

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date	
Ambient dose rate	0.050	Jul 31, 2014	9:00 AM

○The place No.4 where rainwater is sprinkled

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]		Measurement date	
Radioactive material density in the air (Particle)	Cs-134	ND (2.7E-6)	Jul 31, 2014	8:35 AM ~ 8:45 AM
	Cs-137	ND (2.3E-6)		

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date	
Ambient dose rate	0.009	Jul 24, 2014	8:35 AM

Ends