

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (5.8E-01)	ND (6.9E-01)	Treated water tank	9/22	4:00 PM
Cs-137	ND (5.8E-01)	ND (8.2E-01)			
Gross β	ND (4.2E+00)	ND (4.3E+00)			
Tritium	1.7E+02	1.2E+02	Receiving tank	Sep 19, 2014	3:30 PM
Notification density rate*	0.16	0.17			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.