
Sampling Results of Sub-drain Water Regarding Wrong Transfer of Accumulated Water to the Incineration Workshop Building

	East side of the Incineration Workshop Building	
Date of sampling	May 25, 2014	May 26, 2014
Time of sampling	7:54 AM	7:49 AM
Gross β (Bq/cm³)	0.015	0.020
Tritium (Bq/cm ³)	ND(0.12)	Under analysis

Half-life of tritium: Approx 12 years

* Data announced this time is provided in a thick-frame. The other data was announced on May 25.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



High Temperature Incinerator Building

Central Radioactive Waste Treatment Facility