Unit: Ba/L

68

				Unit: Bq/L
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)
Date of Sampling	May 3, 2014	May 3, 2014		
Time of sampling	7:48 AM	7:38 AM		
Cs-134(Approx. 2 years)	ND(1.3)	ND(16)		
Cs-137(Approx.30 years)	ND(1.3)	ND(24)		
Gross β	ND(21)	50		

		Offit. bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Date of Sampling	May 3, 2014	May 3, 2014
Time of sampling	7:43 AM	7:45 AM
Cs-134(Approx. 2 years)	ND(17)	ND(18)
Cs-137(Approx.30 years)	ND(24)	ND(27)

Drainage channel C

B south area

Gross B

Drainage channel B

Note 2: Water inflow location of drainage channel to the tank area

<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35	Point near the main gate in the drainage channel C Note 2 (C-0)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 (9/26)	20 <2/15>
Cs-137(Approx.30 years)	8.1 (9/15,11/9)	130 [9/26]	51 <2/15>
Gross β	ND	2,500 [10/24]	120 <2/15>

Linit: Da/I

			Utilit. Bq/L
	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Cs-134(Approx. 2 years)	110 <5/1>	450 (10/4)	260 [11/10]
Cs-137(Approx.30 years)	280 <5/1>	990 (10/4)	530 [11/10]
Gross β	380 (9/2)	15,000 [10/2]	15,000 [10/14]

^{*} Sampling date is provided in parentheses. []: 2013, <>: 2014

T-2 Seawater of the south water (near the drainage channel exit)

> C-2 Drainage channel C O.P.35 exit

Point immediately short of the junction with the drainage channel C

Side ditch next to the tank

* There is no outflow from the sampling point X-1 and X-2 to the drainage channel C, since they are completely isolated from the drainage channel C.

* The ducting is provided in the dot line.

Point near Fureai Intersection in the drainage channel B

H4 north area

Tank area

Point near the main gate in the drainage channel C

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.