Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference> June 11, 2014 Tokyo Electric Power Company

Unit:	Bq/L

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B
Date of Sampling	Jun 10, 2014	Jun 10, 2014		Jun 10, 2014
Time of sampling	8:15 AM	8:05 AM		7:50 AM
Cs-134(Approx. 2 years)	ND(1.9)	ND(15)		ND(18)
Cs-137(Approx.30 years)	ND(1.6)	ND(23)		ND(25)
Gross β	ND(18)	38		17

Unit: Bq/L
Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Jun 10, 2014
8:18 AM
ND(17)
34
81

Linit: Ba/L

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

<Reference> The Highest Dose Until the Previous Measurement

<reference> The Highest Dose Until the Previous Measurement Unit:</reference>				
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35	Point near the main gate in the drainage channel C Note 2 (C-0)	
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>	
Cs-137(Approx.30 years)	8.1 (9/15,11/9)	130 [9/26]	51 <2/15>	
Gross β	ND	2,500 [10/24]	120 <2/15>	

	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]
Gross β	380 (9/2)	15,000 [10/2]


^{*} Sampling date is provided in parentheses. []: 2013, <>: 2014

T-2 Seawater of the south water (near the drainage channel

C-2 Drainage channel C O.P.35

Point immediately short of the junction with the drainage channel C

* There is no outflow from the sampling point X-1 and X-2 to the drainage channel C, since they are completely isolated from the drainage channel C.



^{*} The ducting is provided B-0-1 in the dot line.

Point near Fureai Intersection in the drainage channel B

Point near the main gate in the drainage channel C

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.