## Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference> July 8, 2014 Tokyo Electric Power Company

- 1	Init:	Pα	/1
U	ıııı.	DU	4

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B
Date of Sampling	Jul 7, 2014	Jul 7, 2014		
Time of sampling	8:30 AM	8:20 AM		
Cs-134(Approx. 2 years)	ND(1.3)	ND(18)		
Cs-137(Approx.30 years)	ND(1.5)	ND(26)		
Gross β	ND(17)	ND(13)		

	Unit: Bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Date of Sampling	Jul 7, 2014
Time of sampling	8:05 AM
Cs-134(Approx. 2 years)	ND(17)
Cs-137(Approx.30 years)	ND(26)
Gross β	50

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

## <Reference> The Highest Dose Until the Previous Measurement

			Offit. DQ/L
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35	Point near the main gate in the drainage channel C Note 2 (C-0)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>
Gross β	ND	2,500 [10/24]	120 <2/15>


	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]
Gross β	380 [9/2]	15,000 [10/2]

<sup>\*</sup> Sampling date is provided in parentheses. []: 2013, <>: 2014

Seawater of the south water (near the drainage channel Drainage channel C O.P.35

Point immediately short of the junction with the drainage channel C

\* There is no outflow from the sampling point X-1 and X-2 to the drainage channel C, since they are completely isolated from the drainage channel C.



<sup>\*</sup> The ducting is provided in the dot line.

Unit: Ba/L

Point near Fureai Intersection in the drainage channel B

Point near the main gate in the drainage channel C

<sup>\* &</sup>quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.