

Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference>
August 21, 2014
Tokyo Electric Power Company

Unit: Bq/L

| | Seawater of the south water outlet <small>Note 1</small> (near the drainage channel exit) (T-2) | Drainage channel C OP.35 exit (C-2) | Switched drainage channel C OP.35 exit (C-2-1) | Point near the main gate in the drainage channel C <small>Note 2</small> (C-0) | Point near Fureai Intersection in the drainage channel B <small>Note 2</small> (B-0-1) |
|-------------------------|--|-------------------------------------|--|--|--|
| Date of Sampling | Aug 20, 2014 | Aug 20, 2014 | Aug 20, 2014 | Aug 20, 2014 | |
| Time of sampling | 7:42 AM | 7:37 AM | 7:35 AM | 7:25 AM | |
| Cs-134(Approx. 2 years) | ND(1.0) | ND(17) | ND(1.7) | ND(17) | |
| Cs-137(Approx.30 years) | ND(1.2) | ND(25) | ND(2.2) | ND(25) | |
| Gross β | ND(19) | 15 | 17 | ND(11) | |

Unit: Bq/L

| | Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1) |
|-------------------------|---|
| Date of Sampling | Aug 20, 2014 |
| Time of sampling | 7:29 AM |
| Cs-134(Approx. 2 years) | ND(16) |
| Cs-137(Approx.30 years) | 27 |
| Gross β | 75 |

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

| | Seawater of the south water outlet <small>Note 1</small> (near the drainage channel exit) (T-2) | Drainage channel C OP.35 exit (C-2) | Switched drainage channel C OP.35 exit (C-2-1) |
|-------------------------|---|-------------------------------------|--|
| Cs-134(Approx. 2 years) | 3.5 [11/9] | 45 [9/26] | 5.9 <8/11> |
| Cs-137(Approx.30 years) | 8.1 [9/15,11/9] | 130 [9/26] | 15 <8/11> |
| Gross β | ND | 2,500 [10/24] | 53 <8/13> |

| | Point near the main gate in the drainage channel C <small>Note 2</small> (C-0) | Point near Fureai Intersection in the drainage channel B <small>Note 2</small> (B-0-1) | Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1) |
|-------------------------|--|--|---|
| Cs-134(Approx. 2 years) | 20 <2/15> | 110 <5/1> | 450 [10/4] |
| Cs-137(Approx.30 years) | 51 <2/15> | 280 <5/1> | 990 [10/4] |
| Gross β | 120 <2/15> | 380 [9/2] | 15,000 [10/2] |

* Sampling date is provided in parentheses. []: 2013, < >: 2014

