Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling																			
Location	Jan 19	Jan 20	Jan 21	Jan 22	Jan 23	Jan 24	Jan 25	Jan 26	Jan 27	Jan 28	Jan 29	Jan 30	Jan 31	Feb 01	Feb 02	Feb 03			
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
7	ND																		
8	ND																		
9	ND																		

Cs-134(Bq/cm³)

Sampling																			
Location	Jan 19	Jan 20	Jan 21	Jan 22	Jan 23	Jan 24	Jan 25	Jan 26	Jan 27	Jan 28	Jan 29	Jan 30	Jan 31	Feb 01	Feb 02	Feb 03			
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
7	0.049	0.033	0.037	0.049	0.044	0.036	0.037	0.033	0.06	0.034	0.038	0.04	0.059	0.064	0.047	0.055			
8	ND	0.016	ND	ND	ND														
9	ND																		

Cs-137(Bq/cm³)

Sampling																			
Location	Jan 19	Jan 20	Jan 21	Jan 22	Jan 23	Jan 24	Jan 25	Jan 26	Jan 27	Jan 28	Jan 29	Jan 30	Jan 31	Feb 01	Feb 02	Feb 03			
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
7	0.12	0.1	0.1	0.13	0.087	0.12	0.098	0.087	0.14	0.085	0.095	0.11	0.16	0.14	0.14	0.11			
8	ND	ND	ND	ND	0.02	ND	ND	ND	0.019	0.024	ND	ND	0.024	ND	ND	ND			
9	ND																		

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at ⁽⁹⁾ has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx. 0.02Bq/cm³, Cs-137: Approx. 0.02Bq/cm³ (February 3, 2013)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

- <Place of Sampling>
- 1 Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- Southwest of the Process Main Building
- 5 South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- West Side of the Incineration Workshop Building
- North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- (9) Southeast Part of the On-site Bunker Building