Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling Location	Feb 09 Feb 10 Feb 11 Feb 12 Feb 13 Feb 14 Feb 15 Feb 16 Feb 17 Feb 18 Feb 19 Feb 20 Feb 21 Feb 22 Feb 23 Feb 24 Feb 25 Feb 26																			
	Feb 09	Feb 10	Feb 11	Feb 12	Feb 13	Feb 14	Feb 15	Feb 16	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26		
1	*1	ND																		
2	*1	ND	 																	
3	*1	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
⑤	*1	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-		
7	*1	ND																		
8	*1	ND																		
9	*1	ND																		

Cs-134(Bq/cm³)

Sampling	Feb 09 Feb 10 Feb 11 Feb 12 Feb 13 Feb 14 Feb 15 Feb 16 Feb 17 Feb 18 Feb 19 Feb 20 Feb 21 Feb 22 Feb 23 Feb 24 Feb 25 Feb 26																			
Location	Feb 09	Feb 10	Feb 11	Feb 12	Feb 13	Feb 14	Feb 15	Feb 16	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26		
1	*1	ND	ND	ND	ND	ND	0.023	0.046	0.022	ND	0.018	ND								
2	*1	ND																		
3	*1	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
⑤	*1	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-		
7	*1	0.065	0.036	0.039	0.053	0.04	0.046	0.053	0.054	0.048	0.031	0.036	0.059	0.041	0.041	0.033	0.04	0.033		
8	*1	ND	ND	ND	ND	ND	ND	0.024	ND											
9	*1	ND																		

Cs-137(Bq/cm³)

Sampling																				
Location	Feb 09	Feb 10	Feb 11	Feb 12	Feb 13	Feb 14	Feb 15	Feb 16	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26		
1	*1	ND	ND	ND	ND	ND	0.068	0.12	0.12	0.054	0.039	0.025	0.026	0.027	ND	0.022	ND	ND		
2	*1	ND																		
3	*1	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	*1	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-		
7	*1	0.16	0.11	0.095	0.11	0.11	0.1	0.15	0.13	0.12	0.1	0.1	0.13	0.11	0.11	0.093	0.11	0.098		
8	*1	ND	ND	ND	ND	ND	ND	0.073	0.028	ND										
9	*1	ND																		

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at ⁽⁹⁾ has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.008Bq/cm³, Cs-134: Approx. 0.01Bq/cm³, Cs-137: Approx. 0.02Bq/cm³ (February 26, 2013)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

*1 The sampling could not be performed due to the snow on February 9.

- <Place of Sampling>
- 1 Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- Southwest of the Process Main Building
- 5 South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- (7) West Side of the Incineration Workshop Building
- North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 9 Southeast Part of the On-site Bunker Building