Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

TO (Deposit)																		
Sampling																		
Location	Oct 5	Oct 6	Oct 7	Oct 8	Oct 9	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19			
1	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
2	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
3	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
6	-	* 1	ND	-	-	-	-	-	ND	-	-	-	-	-	-			
7	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
8	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
9	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			

Cs-134(Bg/cm³)

03-10-(C3-104(B4/GIII)																		
Sampling																			
Location	Oct 5	Oct 6	Oct 7	Oct 8	Oct 9	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19				
1	ND	* 1	0.019	ND	ND	0.012	ND	ND	ND	* 1	0.018	ND	0.022	ND	ND				
2	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND				
3	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND				
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
5	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND				
6	-	* 1	ND	-	-	-	-	-	ND	-	-	-	-	-	-				
Ī	0.032	* 1	0.015	0.032	0.03	0.021	0.037	0.029	0.049	* 1	0.034	0.016	0.035	0.022	0.039				
8	ND	* 1	0.033	0.043	0.026	0.019	0.018	0.018	0.014	* 1	0.029	0.019	0.02	0.019	0.028				
9	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND				

Cs-137(Bq/cm³)

Sampling																		
Location	Oct 5	Oct 6	Oct 7	Oct 8	Oct 9	Oct 10	Oct 11	Oct 12	Oct 13	Oct 14	Oct 15	Oct 16	Oct 17	Oct 18	Oct 19			
1	ND	* 1	0.041	ND	ND	0.044	ND	ND	ND	* 1	0.056	0.027	0.068	0.022	0.02			
2	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
3	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
(5)	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			
6	-	* 1	ND	-	-	-	-	-	ND	-	-	-	-	-	-			
7	0.083	* 1	0.061	0.098	0.1	0.083	0.11	0.12	0.11	* 1	0.087	0.065	0.13	0.085	0.12			
8	ND	* 1	0.098	0.097	0.061	0.046	0.08	0.058	0.063	* 1	0.089	0.071	0.063	0.067	0.042			
9	ND	* 1	ND	ND	ND	ND	ND	ND	ND	* 1	ND	ND	ND	ND	ND			

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
 * (6) was selected as a sampling location in the upstream of groundwater (sampling done once a

- starting from April 29, 2011) since it became unable to do sampling at 4. * Sampling at 7 (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at (9) has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.
- I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.01Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (October 19, 2014)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

*1 Not sampled because of bad weather (October 6 and 14, 2014)

<Place of Sampling>

- ① Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- 4 Southwest of the Process Main Building
- (5) South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- TWest Side of the Incineration Workshop Building
- ® North Part of the Miscellaneous Solid Waste Volume Reduction Treatment
- 9 Southeast Part of the On-site Bunker Building