

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5:Data unavailable due to replacement of the high dose rate monitoring equipment(9:10 am ~)

※"-": the wind velocity is below 0.5m/s

unit: $\mu\text{Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/4 0:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	16.0	No
2012/4/4 0:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	14.7	No
2012/4/4 0:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	13.0	No
2012/4/4 0:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	14.5	No
2012/4/4 0:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	9.8	No
2012/4/4 0:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	11.1	No
2012/4/4 1:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	11.2	No
2012/4/4 1:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-northwest	14.5	No
2012/4/4 1:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	11.7	No
2012/4/4 1:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.1	No
2012/4/4 1:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	15.5	No
2012/4/4 1:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.2	No
2012/4/4 2:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.6	No
2012/4/4 2:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.5	No
2012/4/4 2:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	16.8	No
2012/4/4 2:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	14.6	No
2012/4/4 2:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.7	No
2012/4/4 2:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.9	No
2012/4/4 3:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	26.8	No
2012/4/4 3:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	19.8	No
2012/4/4 3:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	21.4	No
2012/4/4 3:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	22.9	No
2012/4/4 3:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.8	Yes
2012/4/4 3:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.5	No
2012/4/4 4:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	15.1	Yes
2012/4/4 4:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.8	Yes
2012/4/4 4:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	15.9	No
2012/4/4 4:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	12.0	No
2012/4/4 4:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.5	No
2012/4/4 4:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.5	No
2012/4/4 5:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	6.3	No
2012/4/4 5:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.7	No
2012/4/4 5:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	4.7	No
2012/4/4 5:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.3	No
2012/4/4 5:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	9.1	No
2012/4/4 5:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.5	No
2012/4/4 6:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.7	Yes
2012/4/4 6:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	9.5	Yes
2012/4/4 6:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	7.2	Yes
2012/4/4 6:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.9	No
2012/4/4 6:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.7	Yes
2012/4/4 6:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.4	No
2012/4/4 7:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-northwest	8.2	No
2012/4/4 7:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	11.7	Yes
2012/4/4 7:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	8.1	Yes
2012/4/4 7:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	4.1	Yes
2012/4/4 7:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	12.4	Yes
2012/4/4 7:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.8	Yes
2012/4/4 8:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.8	Yes
2012/4/4 8:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.5	Yes
2012/4/4 8:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	9.5	Yes
2012/4/4 8:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	5.2	Yes
2012/4/4 8:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	3.8	Yes
2012/4/4 8:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.5	Yes
2012/4/4 9:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.3	Yes

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5:Data unavailable due to replacement of the high dose rate monitoring equipment(9:10 am ~)

※"-": the wind velocity is below 0.5m/s

unit: $\mu\text{Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/4 9:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	11.5	No
2012/4/4 9:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.6	No
2012/4/4 9:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	10.9	No
2012/4/4 9:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	10.5	No
2012/4/4 9:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	7.2	No
2012/4/4 10:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	5.6	No
2012/4/4 10:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west	7.5	No
2012/4/4 10:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	7.7	No
2012/4/4 10:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	12.7	Yes
2012/4/4 10:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.0	No
2012/4/4 10:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west	9.0	Yes
2012/4/4 11:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	16.3	No
2012/4/4 11:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west	16.9	No
2012/4/4 11:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	16.9	No
2012/4/4 11:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.1	No
2012/4/4 11:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	15.1	No
2012/4/4 11:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	17.0	No
2012/4/4 12:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.2	No

Fukushima Daini Nuclear Power Plant

2012/4/4
as of 12:00

MP1: 1.5 μ Sv/h(as of 12:00,April 4)
(reference :0.035～0.054 μ Sv/h)

MP2: 1.0 μ Sv/h(as of 12:00,April 4)
(reference:0.042～0.062 μ Sv/h)

MP3: 1.5 μ Sv/h(as of 12:00,April 4)
(reference:0.036～0.052 μ Sv/h)


MP4: 1.3 μ Sv/h(as of 12:00,April 4)
(reference:0.036～0.052 μ Sv/h)

MP5: 1.2 μ Sv/h(as of 09:00,April 4)
(reference:0.040～0.058 μ Sv/h)

MP6: 0.7 μ Sv/h(as of 12:00,April 4)
(reference:0.044～0.064 μ Sv/h)

MP7: 0.5 μ Sv/h(as of 12:00,April 4)
(reference:0.043～0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.