

Monitoring data at Fukushima Daini Nuclear Power Station

※“-”: the wind velocity is below 0.5m/s

unit: $\mu\text{Sv/h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/5/15 18:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	11.6	Yes
2012/5/15 18:30	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	10.7	Yes
2012/5/15 18:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	9.2	Yes
2012/5/15 18:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	9.5	Yes
2012/5/15 19:00	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.4	Yes
2012/5/15 19:10	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	7.8	Yes
2012/5/15 19:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.5	Yes
2012/5/15 19:30	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.7	Yes
2012/5/15 19:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.4	Yes
2012/5/15 19:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	9.5	Yes
2012/5/15 20:00	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	9.7	Yes
2012/5/15 20:10	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	9.8	Yes
2012/5/15 20:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	9.8	Yes
2012/5/15 20:30	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	9.6	Yes
2012/5/15 20:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	10.0	Yes
2012/5/15 20:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	10.3	Yes
2012/5/15 21:00	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	10.0	Yes
2012/5/15 21:10	1.4	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	9.5	Yes
2012/5/15 21:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.6	Yes
2012/5/15 21:30	1.4	0.9	1.3	1.2	1.1	0.6	0.5	south	7.5	Yes
2012/5/15 21:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	7.6	Yes
2012/5/15 21:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	6.5	Yes
2012/5/15 22:00	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	7.0	Yes
2012/5/15 22:10	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	8.4	Yes
2012/5/15 22:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	7.2	Yes
2012/5/15 22:30	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	7.2	Yes
2012/5/15 22:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	4.8	Yes
2012/5/15 22:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	3.5	Yes
2012/5/15 23:00	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south	4.2	Yes
2012/5/15 23:10	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	2.4	Yes
2012/5/15 23:20	1.4	0.9	1.3	1.2	1.1	0.7	0.5	south-southwest	2.1	Yes
2012/5/15 23:30	1.4	0.9	1.3	1.2	1.1	0.6	0.5	west	0.9	Yes
2012/5/15 23:40	1.4	0.9	1.3	1.2	1.1	0.7	0.5	west	1.4	Yes
2012/5/15 23:50	1.4	0.9	1.3	1.2	1.1	0.7	0.5	northwest	0.8	Yes

Fukushima Daini Nuclear Power Plant

2012/5/15
as of 23:50

MP1: 1.4 μ Sv/h(as of 23:50,May 15)
(reference :0.035~0.054 μ Sv/h)

MP2: 0.9 μ Sv/h(as of 23:50,May 15)
(reference:0.042~0.062 μ Sv/h)

MP3: 1.3 μ Sv/h(as of 23:50,May 15)
(reference:0.036~0.052 μ Sv/h)


MP4: 1.2 μ Sv/h(as of 23:50,May 15)
(reference:0.036~0.052 μ Sv/h)

MP5: 1.1 μ Sv/h(as of 23:50,May 15)
(reference:0.040~0.058 μ Sv/h)

MP6: 0.7 μ Sv/h(as of 23:50,May 15)
(reference:0.044~0.064 μ Sv/h)

MP7: 0.5 μ Sv/h(as of 23:50,May 15)
(reference:0.043~0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.