

Monitoring data at Fukushima Daini Nuclear Power Station

MP-3 Data missing due to regular inspection(9:40 ~)

※"-": the wind velocity is below 0.5m/s

unit: $\mu\text{Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/7/12 0:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	10.0	No
2012/7/12 0:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	10.2	No
2012/7/12 0:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	9.5	No
2012/7/12 0:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	9.9	No
2012/7/12 0:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	9.7	No
2012/7/12 0:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	9.3	No
2012/7/12 1:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	10.5	No
2012/7/12 1:10	1.3	0.9	1.2	1.2	1.1	0.6	0.5	south-southwest	10.6	No
2012/7/12 1:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	9.0	No
2012/7/12 1:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	13.7	No
2012/7/12 1:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	13.4	No
2012/7/12 1:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	11.5	No
2012/7/12 2:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	13.0	No
2012/7/12 2:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	13.3	No
2012/7/12 2:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	12.7	No
2012/7/12 2:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	12.4	No
2012/7/12 2:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	13.1	No
2012/7/12 2:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	12.0	No
2012/7/12 3:00	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	12.9	No
2012/7/12 3:10	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	13.0	No
2012/7/12 3:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	11.7	No
2012/7/12 3:30	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	11.1	No
2012/7/12 3:40	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	12.9	No
2012/7/12 3:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	13.0	No
2012/7/12 4:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	11.4	No
2012/7/12 4:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	11.3	No
2012/7/12 4:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	10.1	Yes
2012/7/12 4:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	11.5	Yes
2012/7/12 4:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	12.5	Yes
2012/7/12 4:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	11.2	Yes
2012/7/12 5:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	11.1	Yes
2012/7/12 5:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	11.2	Yes
2012/7/12 5:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	9.9	Yes
2012/7/12 5:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	10.0	Yes
2012/7/12 5:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	11.3	No
2012/7/12 5:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	10.6	No
2012/7/12 6:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	10.1	No
2012/7/12 6:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	9.5	No
2012/7/12 6:20	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	13.2	No
2012/7/12 6:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	16.1	No
2012/7/12 6:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	16.9	Yes
2012/7/12 6:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	14.7	No
2012/7/12 7:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south-southwest	16.0	No
2012/7/12 7:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	14.5	No
2012/7/12 7:20	1.3	0.9	1.2	1.2	1.1	0.6	0.5	south-southwest	15.1	Yes
2012/7/12 7:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	15.3	Yes
2012/7/12 7:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	15.7	Yes
2012/7/12 7:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	14.9	Yes
2012/7/12 8:00	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	14.2	No
2012/7/12 8:10	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south	13.5	Yes
2012/7/12 8:20	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	14.4	Yes
2012/7/12 8:30	1.3	0.9	1.3	1.2	1.1	0.6	0.4	south	12.6	Yes
2012/7/12 8:40	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	12.9	Yes
2012/7/12 8:50	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	13.6	Yes
2012/7/12 9:00	1.3	0.9	1.3	1.2	1.1	0.6	0.5	south-southwest	13.5	Yes

Monitoring data at Fukushima Daini Nuclear Power Station

MP-3 Data missing due to regular inspection(9:40 ~)

※“-”: the wind velocity is below 0.5m/s

unit: $\mu\text{Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/7/12 9:10	1.3	0.9	1.2	1.2	1.1	0.6	0.5	south-southwest	12.3	Yes
2012/7/12 9:20	1.3	0.9	1.2	1.2	1.1	0.6	0.4	south-southwest	12.3	Yes
2012/7/12 9:30	1.3	0.9	1.2	1.2	1.1	0.6	0.5	south-southwest	9.8	Yes
2012/7/12 9:40	1.3	0.9	-	1.2	1.1	0.6	0.5	south	12.4	Yes
2012/7/12 9:50	1.3	0.9	-	1.2	1.1	0.6	0.4	south	11.5	Yes
2012/7/12 10:00	1.3	0.9	-	1.2	1.1	0.6	0.5	south-southwest	10.0	Yes
2012/7/12 10:10	1.3	0.9	-	1.2	1.1	0.6	0.5	south-southwest	11.8	Yes
2012/7/12 10:20	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	11.1	Yes
2012/7/12 10:30	1.3	0.9	-	1.2	1.1	0.6	0.5	south-southwest	11.9	Yes
2012/7/12 10:40	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	12.6	Yes
2012/7/12 10:50	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	11.8	Yes
2012/7/12 11:00	1.3	0.9	-	1.2	1.1	0.6	0.5	south-southwest	12.4	Yes
2012/7/12 11:10	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	11.8	Yes
2012/7/12 11:20	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	13.3	Yes
2012/7/12 11:30	1.3	0.9	-	1.2	1.1	0.6	0.4	south-southwest	15.4	Yes
2012/7/12 11:40	1.3	0.9	-	1.1	1.1	0.6	0.4	south-southwest	14.4	Yes
2012/7/12 11:50	1.3	0.9	-	1.1	1.1	0.6	0.4	south-southwest	12.4	Yes
2012/7/12 12:00	1.3	0.9	-	1.1	1.1	0.6	0.4	south-southwest	13.1	Yes

Fukushima Daini Nuclear Power Plant

2012/7/12
as of 12:00

MP1: 1.3 μ Sv/h(as of 12:00,July 12)
(reference :0.035～0.054 μ Sv/h)

MP2: 0.9 μ Sv/h(as of 12:00,July 12)
(reference:0.042～0.062 μ Sv/h)

MP3: 1.2 μ Sv/h(as of 09:30,July 12)
(reference:0.036～0.052 μ Sv/h)


MP4: 1.1 μ Sv/h(as of 12:00,July 12)
(reference:0.036～0.052 μ Sv/h)

MP5: 1.1 μ Sv/h(as of 12:00,July 12)
(reference:0.040～0.058 μ Sv/h)

MP6: 0.6 μ Sv/h(as of 12:00,July 12)
(reference:0.044～0.064 μ Sv/h)

MP7: 0.4 μ Sv/h(as of 12:00,July 12)
(reference:0.043～0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.