

Monitoring data at Fukushima Daini Nuclear Power Station

※"-": the wind velocity is below 0.5m/s

unit: $\mu\text{Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/3/5 0:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-southwest	1.1	No
2012/3/5 0:10	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west	0.8	No
2012/3/5 0:20	1.5	1.0	1.5	1.3	1.1	0.7	0.5	southwest	1.4	No
2012/3/5 0:30	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west-southwest	1.3	No
2012/3/5 0:40	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west-southwest	2.5	Yes
2012/3/5 0:50	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west	2.6	Yes
2012/3/5 1:00	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west	2.7	Yes
2012/3/5 1:10	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west	2.1	Yes
2012/3/5 1:20	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west-northwest	1.9	Yes
2012/3/5 1:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	northwest	1.6	Yes
2012/3/5 1:40	1.5	1.0	1.5	1.3	1.1	0.7	0.5	west-southwest	3.5	Yes
2012/3/5 1:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	southwest	1.8	Yes
2012/3/5 2:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-southwest	2.6	Yes
2012/3/5 2:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-northwest	0.8	Yes
2012/3/5 2:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-southwest	2.9	Yes
2012/3/5 2:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-southwest	3.1	Yes
2012/3/5 2:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west	2.2	Yes
2012/3/5 2:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-northwest	2.2	Yes
2012/3/5 3:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west	2.7	Yes
2012/3/5 3:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west	2.8	Yes
2012/3/5 3:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west	2.9	Yes
2012/3/5 3:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-northwest	2.1	Yes
2012/3/5 3:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	west-northwest	1.3	Yes
2012/3/5 3:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	northwest	1.0	Yes
2012/3/5 4:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northeast	2.5	Yes
2012/3/5 4:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northeast	3.1	Yes
2012/3/5 4:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	3.7	Yes
2012/3/5 4:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	3.9	Yes
2012/3/5 4:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	4.3	Yes
2012/3/5 4:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	4.7	Yes
2012/3/5 5:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	4.8	Yes
2012/3/5 5:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	5.7	Yes
2012/3/5 5:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	5.7	Yes
2012/3/5 5:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	5.4	Yes
2012/3/5 5:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	5.3	Yes
2012/3/5 5:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	5.5	Yes
2012/3/5 6:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	4.8	Yes
2012/3/5 6:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	5.8	Yes
2012/3/5 6:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.1	Yes
2012/3/5 6:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	5.3	Yes
2012/3/5 6:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	6.9	Yes
2012/3/5 6:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	8.0	Yes
2012/3/5 7:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.4	Yes
2012/3/5 7:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.8	Yes
2012/3/5 7:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.7	Yes
2012/3/5 7:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.0	Yes
2012/3/5 7:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.1	Yes
2012/3/5 7:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.8	Yes
2012/3/5 8:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	6.5	Yes
2012/3/5 8:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.4	Yes
2012/3/5 8:20	1.4	1.0	1.4	1.3	1.1	0.7	0.5	north	6.9	Yes
2012/3/5 8:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	7.0	Yes
2012/3/5 8:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	6.5	Yes
2012/3/5 8:50	1.4	1.0	1.4	1.3	1.1	0.7	0.5	north	8.8	Yes
2012/3/5 9:00	1.4	1.0	1.4	1.3	1.1	0.7	0.5	north	6.8	Yes

Monitoring data at Fukushima Daini Nuclear Power Station

※"-": the wind velocity is below 0.5m/s

unit: $\mu\text{ Sv}/\text{h}$

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/3/5 9:10	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.2	Yes
2012/3/5 9:20	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.7	Yes
2012/3/5 9:30	1.4	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	7.5	Yes
2012/3/5 9:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	6.4	Yes
2012/3/5 9:50	1.4	1.0	1.4	1.3	1.1	0.7	0.5	north	7.7	Yes
2012/3/5 10:00	1.4	1.0	1.4	1.2	1.1	0.7	0.5	north	9.0	Yes
2012/3/5 10:10	1.4	0.9	1.4	1.2	1.1	0.7	0.5	north	7.2	Yes
2012/3/5 10:20	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north	6.6	Yes
2012/3/5 10:30	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north-northwest	6.3	Yes
2012/3/5 10:40	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north	6.7	Yes
2012/3/5 10:50	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north-northwest	6.9	Yes
2012/3/5 11:00	1.5	0.9	1.4	1.2	1.1	0.7	0.5	north-northwest	7.2	Yes
2012/3/5 11:10	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north-northwest	6.5	Yes
2012/3/5 11:20	1.5	1.0	1.4	1.2	1.1	0.7	0.5	north	7.1	Yes
2012/3/5 11:30	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	6.1	Yes
2012/3/5 11:40	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	6.1	Yes
2012/3/5 11:50	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north-northwest	6.4	Yes
2012/3/5 12:00	1.5	1.0	1.4	1.3	1.1	0.7	0.5	north	5.5	Yes

Fukushima Daini Nuclear Power Plant

2012/3/5
as of 12:00

MP1: 1.5 μ Sv/h(as of 12:00,March 5)
(reference :0.035～0.054 μ Sv/h)

MP2: 1.0 μ Sv/h(as of 12:00,March 5)
(reference:0.042～0.062 μ Sv/h)

MP3: 1.4 μ Sv/h(as of 12:00,March 5)
(reference:0.036～0.052 μ Sv/h)


MP4: 1.3 μ Sv/h(as of 12:00,March 5)
(reference:0.036～0.052 μ Sv/h)

MP5: 1.1 μ Sv/h(as of 12:00,March 5)
(reference:0.040～0.058 μ Sv/h)

MP6: 0.7 μ Sv/h(as of 12:00,March 5)
(reference:0.044～0.064 μ Sv/h)

MP7: 0.5 μ Sv/h(as of 12:00,March 5)
(reference:0.043～0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.