

Results of Measurement of Dose Equivalent Rate at Fukushima Daini Nuclear Power Station Unit 1

Atmosphere Dose Equivalent Rate

Measured Atmosphere Dose Equivalent Rate in D/W, geometric mean value at each floor

(Unit: mSv/h)

	Last Periodical Inspection	Shutdown This Time (December 27, 2011)
OP40m	0.08	0.02
OP37m	0.06	0.03
OP32m	0.07	0.06
OP28m	0.15	0.13
OP22m	0.11	0.10
OP18m	0.13	0.09

