

Water leakage seemed to be caused by congelation in Fukushima Daiichi Nuclear Power Station (Confirmed on February 3rd)

February 3, 2012
Tokyo Electric Power Company

No	Date and Time of Occurrence (Date and Time of stop or isolation)	Leaked Place/Point	Amount of Leaked Water	With/Without Dam	Radioactivity Density (Bq/cm ³)	Flow Out to Ocean	Influence to System	Atmosphere Dose Rate (mSv/h)
	11:25 Feb. 3, 2012 (14:30 isolated by closing upper stream valve)	Flange connecting valve of discharge ball valve at header for purified water supply hyaline washing piping(Purified water supply line) and the elbow	Now Confirming	Without	filtrate water	No	No	The same as that of back ground