

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building < 1/3 >

(Data summarized on July 10)

Place of Sampling	Upper Part of Unit 1 Reactor Building (Entrance of cover exhaust system filter) (particulate filter)		Upper Part of Unit 1 Reactor Building (Entrance of cover exhaust system filter) (charcoal filter)		Upper Part of Unit 1 Reactor Building (Exit of cover exhaust system filter) (particulate filter)		Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Jul 2, 2012 4:47 PM - 5:47 PM	Jul 2, 2012 10:50 AM - 11:00 AM	Jul 2, 2012 10:30 AM - 11:30 AM			
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	1.2E-05	0.01	ND	-	ND	-	2E-03
Cs-137 (Approx. 30 years)	1.8E-05	0.01	ND	-	ND	-	3E-03

* O.OE - O is the same as O.O x 10^{-O}

* Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 4E-6Bq/cm³, Cs-134: Approx.9E-6Bq/cm³, Cs-137: Approx.1E-5Bq/cm³

Particulate: I-131: Approx. 8E-7Bq/cm³, Cs-134: Approx.1E-6Bq/cm³, Cs-137: Approx.2E-6Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Reference

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building < 2/3 >

(Data summarized on July 10)

Place of Sampling	Upper Part of Unit 1 Reactor Building (The Exit of Cover Exhaust System Filter) (Charcoal filter)		Upper Part of Unit 1 Reactor Building (Northwest corner of the cover) (Particulate filter)		Upper Part of Unit 1 Reactor Building (Northeast corner of the cover) (Particulate filter)		Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Jul 2, 2012 11:30 AM - 11:40 AM	Time of Sampling	Jul 2, 2012 8:47 AM - 9:47 AM	Time of Sampling	Jul 2, 2012 7:47 AM - 8:47 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	ND	-	5.4E-06	0.00	3.6E-06	0.00	2E-03
Cs-137 (Approx. 30 years)	ND	-	9.7E-06	0.00	5.2E-06	0.00	3E-03

* O.OE - O is the same as O.O x 10⁻⁰

* Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 5E-6Bq/cm³, Cs-134: Approx.9E-6Bq/cm³, Cs-137: Approx.1E-5Bq/cm³
 Particulate: I-131: Approx. 7E-7Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Reference

Nuclides Analysis Result of the Radioactive Materials in the Air at the Upper Part of Unit 1 Reactor Building < 3/3 >

(Data summarized on July 10)

Place of Sampling	Upper Part of Unit 1 Reactor Building (Southwest corner of the cover)		Upper Part of Unit 1 Reactor Building (Reactor Building operation floor opening)		Upper Part of Unit 1 Reactor Building (Ceiling of spent fuel pool)		Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	Jul 2, 2012 9:47 AM - 10:47 AM		Jul 2, 2012 6:47 PM - 7:47 PM		Jul 2, 2012 5:47 PM - 6:47 PM		
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	3.0E-06	0.00	ND	-	1.0E-05	0.01	2E-03
Cs-137 (Approx. 30 years)	3.4E-06	0.00	1.9E-06	0.00	1.8E-05	0.01	3E-03

* O.OE - O is the same as O.O x 10⁻⁰

* Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. I-131: Approx. 7E-7Bq/cm³, Cs-134: Approx.1E-6Bq/cm³
 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected. This shows the nuclides analysis results of particulate radioactive materials in the air.

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected. This shows the nuclides analysis results of particulate radioactive materials in the air.