

< Attachment 1 >

Result of measurement of radioactive materials in Kashiwazaki-Kariwa Nuclear Power Plant

| Observation points | | Nuclides | Measured value (Bq/cm ³) | Lowest Detectable Level (Bq/cm ³) | Upper Concentration Limit in the Air Bq/cm ³ (Limit in announcement) |
|------------------------|-----------------------------|------------|---|--|--|
| Dust radiation monitor | 1 (By Monitoring Post 1) | Cesium 134 | 5.8×10^{-12} | 3.8×10^{-12} | 2×10^{-5} |
| | | Cesium 137 | Below lowest detectable level | 3.2×10^{-12} | 3×10^{-5} |
| | 2 (By Monitoring Post 8) | Cesium 134 | 4.3×10^{-12} | 3.9×10^{-12} | 2×10^{-5} |
| | | Cesium 137 | 3.2×10^{-12} | 2.7×10^{-12} | 3×10^{-5} |
| | 3 (By Monitoring Post 5) | Cesium 134 | 9.3×10^{-12} | 3.9×10^{-12} | 2×10^{-5} |
| | | Cesium 137 | 6.9×10^{-12} | 2.9×10^{-12} | 3×10^{-5} |