

< Attachment-1 >

Result of measurement of Iodine 131 in Kashiwazaki-Kariwa Nuclear Power Plant

[Exhaust stack and Exhaust vent of building]

Monitoring point		Iodine 131 (Bq/cm ³)	Minimum Detectable Density (Bq/cm ³)	Upper Concentration Limit in the Air Bq/cm ³ (Density in announcement)
Exhausts stack	Unit 1	7.8×10^{-9}	5.0×10^{-9}	5×10^{-6}
	Unit 2	6.2×10^{-9}	4.8×10^{-9}	
	Unit 3	Not detected	4.5×10^{-9}	
	Unit 4	7.6×10^{-9}	4.3×10^{-9}	
	Unit 5	9.1×10^{-9}	4.5×10^{-9}	
	Unit 6	6.6×10^{-9}	5.0×10^{-9}	
	Unit 7	9.5×10^{-9}	4.6×10^{-9}	
Exhaust vent of service building	Unit 3	9.8×10^{-9}	2.3×10^{-9}	
	Unit 5	9.4×10^{-9}	4.5×10^{-9}	
	Unit 6	8.8×10^{-9}	5.4×10^{-9}	
Auxiliary building		Not detected	4.1×10^{-9}	
Exhaust vent of incineration building (Arahama-side)		Not detected	4.8×10^{-9}	
Exhaust vent of incineration building (Oominato-side)		Not detected	4.8×10^{-9}	

END