

The result of the nuclide analysis of radioactive materials in the air  
at the site of Fukushima Nuclear Power Station

Reference

( Data summarized on April 28 )

Place of sampling		West gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3)	
Date and time of sampling		11:27 am - 11:47 am April 27th, 2011		9:22 am - 9:30 am April 27th, 2011		3:27 pm - 3:35 pm April 27th, 2011			
Detected nuclide (half-life)		Radioactivity density (Bq/cm3)	Scaling factor ( / )	Radioactivity density (Bq/cm3)	Scaling factor ( / )	Radioactivity density (Bq/cm3)	Scaling factor ( / )		
Volatile	I-131 (approx. 8 days)	5.1E-05	0.05	8.9E-06	0.01	5.2E-06	0.01	1E-03	
	Cs-134 (approx. 2 years)	ND	-	9.0E-06	0.00	1.3E-05	0.01	2E-03	
	Cs-137 (approx 30 years)	1.2E-05	0.00	1.0E-05	0.00	1.5E-05	0.01	3E-03	
Particle	I-131 (approx. 8 days)	4.7E-05	0.05	4.0E-06	0.00	4.8E-06	0.00	1E-03	
	Cs-134 (approx. 2 years)	1.3E-05	0.01	7.0E-06	0.00	6.6E-06	0.00	2E-03	
	Cs-137 (approx. 30 years)	1.3E-05	0.00	6.4E-06	0.00	8.3E-06	0.00	3E-03	

Statutory density limit to the 3-month average density of radioactive nuclides contained in the air that humans breathe.

. E - means . x 10 -

Data of other nuclides are under examination.