Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 2)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/6/1 11:00	2011/6/1 12:00	2011/6/1 12:05	2011/6/1 12:05	2011/6/1 11:45	2011/6/1 11:35	2011/6/1 11:45
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm³)						
I-131 (about 8 days)	4.6E+00	2.4E+00	1.9E+00	7.7E-02	ND	ND	ND
Cs-134 (about 2 years)	6.4E+01	7.7E+00	1.4E+00	9.5E-01	7.8E-03	8.6E-03	ND
Cs-137 (about 30 years)	7.8E+01	9.2E+00	1.6E+00	1.0E+00	1.1E-02	8.5E-03	ND

[.] E - means . x10.

Data of other nuclides are under evaluation.

ND: when the detected amount is below the detection limit in this analysis (I-131: approx. 4E-3Bq/cm3, Cs-134: approx. 6E-3Bq/cm3, Cs-137: approx. 7E-3Bq/cm3)