

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 18)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	11:54 am June 17, 2011	11:49 am June 17, 2011	11:44 am June 17, 2011	11:38am June 17, 2011	11:29 am June 17, 2011	11:20 am June 17, 2011	9:32 am June 17, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	4. 1E-02	7. 5E-01	ND	9. 0E-03	ND	ND	ND
Cs-134 (about 2 years)	3. 3E+00	1. 1E+01	8. 8E-02	2. 3E-02	ND	ND	ND
Cs-137 (about 30 years)	4. 0E+00	1. 3E+01	1. 1E-01	2. 2E-02	ND	ND	ND

※ 〇.OE-〇 means 〇.〇×10.

※ Data of other nuclides are under evaluation.

※ ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 1E-2Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 2E-2Bq/cm³). However, nuclides below limits might be detected since detection limits depend on detector and condition of sample.