

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on July 5)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	July 4, 2011 12:00	July 4, 2011 11:53	July 4, 2011 11:40	July 4, 2011 11:23	July 4, 2011 11:30	July 4, 2011 11:23	July 4,2011 10:05
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	ND	1.3E-01	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	3.4E+00	9.6E+00	4.7E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	4.2E+00	1.2E+01	4.1E-02	ND	ND	ND	ND

. E - means . ×10.

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 4E-2Bq/cm³, Cs-134: approx. 3E-2Bq/cm³, Cs-137: approx.4E-2Bq/cm³). However, nuclides below limits might be detected since detection limits depend on detector and sample.