

## Nuclide Analysis Results of Seawater <Coast>

Reference

( Data summarized on : July 25 )

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)	Around South Discharge Channel of 1F ( approx. 330m south of 1-4u Discharge Channel)				Around North Discharge Channel of 2F ( Around 3,4u Discharge Channel) ( approx. 10 km from 1F )	Around Iwasawa Shore of 2F ( approx. 7 km south of 1,2u Discharge Channel) ( approx. 16 km from 1F )		Density limit by the announcement of Reactor Regulation (Bq/L)				
Time and Date of Sample Collection	Cancelled July 24, 2011	Cancelled July 24, 2011		N/A		8:00 am July 24, 2011	7:35 am July 24, 2011		(the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)				
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )					
I-131 (about 8 days)	/	/	/	/	/	/	ND	-			ND	-	40
Cs-134 (about 2 years)	/	/	/	/	/	/	6.0	0.10			ND	-	60
Cs-137 (about 30 years)	/	/	/	/	/	/	5.5	0.06	5.4	0.06	90		

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm<sup>3</sup> to Bq/L.

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit, "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 3Bq/L., Cs-134: approx. 4Bq/L.

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.