

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater <1/3>
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 11)

Place of Collection	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	80	1.3	96	1.6	90	1.5	89	1.5	170	2.8	60
Cs-137 (about 30 years)	72	0.80	84	0.93	130	1.4	110	1.2	180	2.0	90

* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

* Data of other nuclides are under evaluation.

* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 16Bq/L, Cs-137: approx. 29Bq/L), "ND" is represented.

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater <2/3>
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 11)

Place of Collection	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	80	1.3	96	1.6	90	1.5	89	1.5	170	2.8	60
Cs-137 (about 30 years)	72	0.80	84	0.93	130	1.4	110	1.2	180	2.0	90

* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

* Data of other nuclides are under evaluation.

* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 29Bq/L), "ND" is represented.

Reference

Nuclide Analysis Results of Radioactive Materials in Seawater <3/3>
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 11)

Place of Collection	Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi Nuclear Power Plant						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)	
	Time and date of sample collection	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)		Scaling factor (/)
2011/8/10 7:25 AM	2011/8/10 7:30 AM	2011/8/10 1:30 PM										
I-131 (about 8 days)	ND	-	ND	-	ND	-						40
Cs-134 (about 2 years)	91	1.5	240	4.0	ND	-						60
Cs-137 (about 30 years)	99	1.1	240	2.7	ND	-						90

* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

* Data of other nuclides are under evaluation.

* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 24Bq/L), "ND" is represented.