

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

| |
|-----------|
| Reference |
|-----------|

(Data summarized on October 22)

| Place of Sampling | Fukushima Daiichi NPS 1U sub-drain | Fukushima Daiichi NPS 2U sub-drain | Fukushima Daiichi NPS 3U sub-drain | Fukushima Daiichi NPS 4U sub-drain | Fukushima Daiichi NPS 5U sub-drain | Fukushima Daiichi NPS 6U sub-drain | Fukushima Daiichi NPS Deep well |
|----------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|------------------------------------|
| Time of Sampling | 10/21/2011 10:05 AM | 10/21/2011 10:10 AM | 10/21/2011 10:20 AM | 10/21/2011 10:08 AM | 10/21/2011 10:00 AM | 10/21/2011 9:55 AM | 10/21/2011 9:40 AM |
| Detected Nuclides (Half-life) | Density of sample (Bq/cm3) | | | | | | |
| I-131 (about 8 days) | ND | ND | ND | ND | ND | ND | ND |
| Cs-134 (about 2 years) | 7.0E-01 | 9.5E-01 | ND | ND | ND | ND | ND |
| Cs-137 (about 30 years) | 9.8E-01 | 1.2E+00 | ND | ND | ND | ND | ND |

* O.OE - O means O.O x 10-O

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit. I-131: approx. 3E-2Bq/cm3, Cs-134: approx. 3E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3)
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.