

Result of Pu Analysis of the air at Fukushima Daiichi Nuclear Power Station

1. Place of Sampling: West Gate of Fukushima Daiichi Nuclear Power Station
2. Organization: Japan Chemical Analysis Center
3. Result of Analysis :

(Unit: mBq/m³)

Detected Nuclides	Date of Sampling	Pu-238	Pu-239,Pu-240
Volatile	10/3	N.D. [$<7.4 \times 10^{-1}$]	N.D. [$<7.2 \times 10^{-1}$]
Particle		N.D. [$<8.3 \times 10^{-1}$]	N.D. [$<8.3 \times 10^{-1}$]

Detection limits are shown in [].

4. Evaluation:

No Pu-238,Pu-239,Pu-240 was detected in the samples this time.

End