

(Aggregation period: March 11, 2011 - March 31, 2016)

Table 16 Cumulative Data of Equivalent Dose to the Lens of the Eye by Fisical Year

FY2011

Dose ranges (mSv)	March 2011-March 2012		
	TEPCO's employees	Contractors	Total
Above 200	0	0	0
150-200	7	3	10
100-150	59	8	67
75-100	108	29	137
50-75	233	236	469
20-50	671	2492	3163
10-20	555	2820	3375
5-10	427	2568	2995
1-5	599	4717	5316
1 or less	756	4845	5601
Total	3415	17718	21133
Maximum (mSv)	188.14	199.42	199.42
Average (mSv)	19.21	9.34	10.93

- Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the lens of the eye is 150mSv/year (the emergency exposure dose limit is 300mSv).
- Seven TEPCO's employees and three contractors shown in the "150-200"cell of the dose range above were exposed to radiation during the period when the dose limit for radiation workers engaged in emergency work was set at 300mSv.

FY2012

Dose ranges (mSv)	April 2012-March 2013		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	0	0
50-75	1	54	55
20-50	65	733	798
10-20	133	1970	2103
5-10	259	1843	2102
1-5	580	3295	3875
1 or less	588	4221	4809
Total	1626	12116	13742
Maximum (mSv)	55.60	67.30	67.30
Average (mSv)	4.55	6.31	6.10

FY2013

Dose ranges (mSv)	April 2013-March 2014		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	1	1
75-100	0	1	1
50-75	2	34	36
20-50	52	835	887
10-20	100	2050	2150
5-10	210	1830	2040
1-5	644	3619	4263
1 or less	684	4684	5368
Total	1692	13054	14746
Maximum (mSv)	68.30	106.88	106.88
Average (mSv)	3.78	6.10	5.83

FY2014

Dose ranges (mSv)	April 2014-March 2015		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	0	0
50-75	1	70	71
20-50	12	1232	1244
10-20	68	2605	2673
5-10	159	2640	2799
5-1	630	5182	5812
1 or less	818	7313	8131
Total	1688	19042	20730
Maximum (mSv)	56.50	62.91	62.91
Average (mSv)	2.42	5.97	5.68

FY2015

Dose ranges (mSv)	April 2015-March 2016		
	TEPCO's employees	Contractors	Total
Above 150	0	0	0
100-150	0	0	0
75-100	0	6	6
50-75	0	42	42
20-50	8	878	886
10-20	52	2076	2128
5-10	113	2181	2294
5-1	535	4780	5315
1 or less	988	6518	7506
Total	1696	16481	18177
Maximum (mSv)	24.43	87.74	87.74
Average (mSv)	1.90	5.30	4.99

Note)

- The values of the exposure dose and the number of the workers in the table above are subject to change, because there are times when APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Main Anti-earthquake Building) need to be updated in the table after the publication of the data.